



AN-324

Enhanced Smart Reader Outputs in Protege WX

Application Note



The specifications and descriptions of products and services contained in this document were correct at the time of printing. Integrated Control Technology Limited reserves the right to change specifications or withdraw products without notice. No part of this document may be reproduced, photocopied, or transmitted in any form or by any means (electronic or mechanical), for any purpose, without the express written permission of Integrated Control Technology Limited. Designed and manufactured by Integrated Control Technology Limited, Protege® and the Protege® Logo are registered trademarks of Integrated Control Technology Limited. All other brand or product names are trademarks or registered trademarks of their respective holders.

Copyright © Integrated Control Technology Limited 2003-2021. All rights reserved.

Last Published: 22-Oct-21 12:02 PM

Contents

Introduction	4
Prerequisites	4
Enabling Enhanced Smart Reader Outputs	5
Reader Outputs Table	5

Introduction

The purpose of the Enhanced Smart Reader Outputs option in Protege WX is to allow individual control of reader port outputs (i.e. reader LEDs and beepers), so they can be activated independently.

Unlike Wiegand configuration, in ICT RS485 mode the beeper and LEDs on the reader are controlled within the reader itself, not directly from the reader expander's BZ, L1 and L2 connections. Wiring the reader in RS-485 configuration leaves the BZ, L1 and L2 available for connection to additional devices. Enhanced Smart Reader Output configuration provides independent control over these outputs, enabling full use of all the outputs available on the reader expander.

Under normal operation without Enhanced Smart Reader Outputs enabled, if you activate the reader LEDs or beeper the physical reader expander output will be activated **and** a message will be sent to the entry and exit reader connected to that port to light the LED or sound the beeper.

With the Enhanced Smart Reader Outputs option enabled, when you activate the reader output only the reader port's **physical reader output** will change state, and trigger any device connected to it. The physical reader's LEDs and beeper will not be affected as they are controlled independently, through their own outputs.

This application note provides instructions on programming Enhanced Smart Reader Outputs in Protege WX.

Prerequisites

Only the reader ports on controllers and reader expanders support the ICT RS485 functionality required to implement this feature. The following modules support this functionality:

Controller Modules	Firmware Version
PRT-WX-DIN	4.00.255 or higher.
PRT-WX-DIN-1D	
Reader Expander Modules	Firmware Version
PRT-RDM2-DIN-485	1.12.509 or higher.
PRT-HRDM-DIN	

- Only RS-485 reader models are compatible with this feature, and must be wired in RS-485 configuration.
- Reader ports must be configured to operate in ICT RS485 mode.

Enabling Enhanced Smart Reader Outputs

A key requirement of this feature is that the reader ports must be operating in ICT RS485 mode. The feature must then be enabled for each reader port.

1. Navigate to **Expanders | Reader Expanders** and select the reader expander to be configured for Enhanced Smart Reader Outputs functionality.
2. In the **Configuration** section, set the **Port 1 Network Type** and/or **Port 2 Network Type** to ICT RS485.
3. Select the **Reader 1/2** tab, scroll down to the **Misc Options** section and check the **Enable Enhanced Smart Reader Outputs** option to enable this feature.
4. When complete, click **Save**.

Reader Outputs Table

The following table defines the available output actions for this feature. The required output records must be added in **Programming | Outputs**, with the appropriate **Module Output** setting for the corresponding function. Each output can then be activated independently by manual commands, door and area operations, programmable functions or a variety of other methods.

Module Output settings 1-8 control the reader expander's physical outputs, while settings 9-20 control the reader LEDs and beepers, independently of the physical outputs themselves.

Module Output	Enhanced Smart Reader Output Action
1	Relay 1
2	Relay 2
3	Port 1 L1 output
4	Port 1 L2 output (PRT-RDM2-DIN-485 only)
5	Port 1 BZ output
6	Port 2 L1 output
7	Port 2 L2 output (PRT-RDM2-DIN-485 only)
8	Port 2 BZ output
9	Port 1 Entry Reader LED
10	Reserved
11	Port 1 Entry Reader Beeper
12	Port 1 Exit Reader LED
13	Reserved
14	Port 1 Exit Reader Beeper
15	Port 2 Entry Reader LED
16	Reserved
17	Port 2 Entry Reader Beeper
18	Port 2 Exit Reader LED
19	Reserved
20	Port 2 Exit Reader Beeper

Designers & manufacturers of integrated electronic access control, security and automation products.
Designed & manufactured by Integrated Control Technology Ltd.
Copyright © Integrated Control Technology Limited 2003-2021. All rights reserved.

Disclaimer: Whilst every effort has been made to ensure accuracy in the representation of this product, neither Integrated Control Technology Ltd nor its employees shall be liable under any circumstances to any party in respect of decisions or actions they may make as a result of using this information. In accordance with the ICT policy of enhanced development, design and specifications are subject to change without notice.