



Ref. Certif. No.

**DK-121248-UL**

**IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME**

**CB TEST CERTIFICATE**

Product	Protege DIN Rail 4A Intelligent Power Supply
Name and address of the applicant	INTEGRATED CONTROL TECHNOLOGY LTD 4 JOHN GLENN AVENUE ROSEDALE AUCKLAND 0632 NEW ZEALAND
Name and address of the manufacturer	INTEGRATED CONTROL TECHNOLOGY LTD 4 JOHN GLENN AVENUE ROSEDALE AUCKLAND 0632 NEW ZEALAND
Name and address of the factory	INTEGRATED CONTROL TECHNOLOGY LTD 4 JOHN GLENN AVENUE ROSEDALE AUCKLAND 0632 NEW ZEALAND
Note: When more than one factory, please report on page 2	<input type="checkbox"/> Additional Information on page 2
Ratings and principal characteristics	AC IN: 100-240 V AC, 50/60 Hz, 2.3 A or 115 V AC, 50/60 Hz, 1.1 A or 230 V AC, 50/60Hz, 2.3 A <input checked="" type="checkbox"/> Additional Information on page 2
Trademark (if any)	
Customer's Testing Facility (CTF) Stage used	
Model / Type Ref.	PRT-PSU-DIN-4A
Additional information (if necessary may also be reported on page 2)	<b>Additionally evaluated to:</b> EN 62368-1:2014/A11:2017, EN 62368-1:2014. National Differences specified in the CB Test Report. <input type="checkbox"/> Additional Information on page 2
A sample of the product was tested and found to be in conformity with	IEC 62368-1:2014
As shown in the Test Report Ref. No. which forms part of this Certificate	E524501-A6001-CB-1 issued on 2021-11-24

This CB Test Certificate is issued by the National Certification Body



- UL (US), 333 Pfingsten Rd IL 60062, Northbrook, USA
- UL (Demko), Borupvang 5A DK-2750 Ballerup, DENMARK
- UL (JP), Marunouchi Trust Tower Main Building 6F, 1-8-3 Marunouchi, Chiyoda-ku, Tokyo 100-0005, JAPAN
- UL (CA), 7 Underwriters Road, Toronto, M1R 3B4 Ontario, CANADA

For full legal entity names see [www.ul.com/ncbnames](http://www.ul.com/ncbnames)

Date: 2021-11-24

Signature:

Jan-Erik Storgaard



Ref. Certif. No.

**DK-121248-UL**

**Additional Ratings:**

DC OUT (Combined):

12 V DC, 4.0 A Max (V1 Out + V2 Out Total)

DC OUT (Single):

12 V DC, 3.0 A Max (V1 Out OR V2 Out)

**Additional information (if necessary)**



- UL (US), 333 Pfingsten Rd IL 60062, Northbrook, USA
- UL (Demko), Borupvang 5A DK-2750 Ballerup, DENMARK
- UL (JP), Marunouchi Trust Tower Main Building 6F, 1-8-3 Marunouchi, Chiyoda-ku, Tokyo 100-0005, JAPAN
- UL (CA), 7 Underwriters Road, Toronto, M1R 3B4 Ontario, CANADA

For full legal entity names see [www.ul.com/ncbnames](http://www.ul.com/ncbnames)

Date: 2021-11-24

Signature:

Jan-Erik Storgaard